

Item	Part #	Description V	Wiring Item #
		, AND THERMOSTATS lard Energy Efficient Fan Andrew Evaporat	• ' '
	0461805	(MO.4410546) Fan Blade (FB.478044	16)
B.	0474033	Standard Non-adjustab Defrost Thermostat (C	* *
C.		Optional Adjustable Refrigeration Thermost	tat (3)
D.	0344662	Defrost Limit Thermost (CT.4440261)	tat (4)
E.	0461814	Relay Control Thermos Fan and Anti-sweat He Thermostat (CT.448129	eater
RELA	YS		
F.	0342598	Anti-Sweat Control R (120V) (RL.4480238)	elay (6)
G.	0342599	Fan Control Relay (2 (RL.4480237)	(08V) (7)

HEATERS

Item Part # (Qty.) Description

H. Electric Defrost Heaters – Front (208V)

3015372 (1) 2 Door Models (HE.4850346)

	3013372 (1)	2 Door Models (112.4030340)
	3015373 (1)	3 Door Models (HE.4850337)
	3015374 (1)	4 Door Models (HE.4850347)
	3015375 (1)	5 Door Models (HE.4850323)
	Electric Defre	ost Heaters — Rear (208V) (8)
	3015376 (1)	2 Door Models (HE.4850358)
	3015377 (1)	3 Door Models (HE.4850359)
	3015378 (1)	4 Door Models (HE.4850360)
	3015379 (1)	5 Door Models (HE.4850361)
I.	Drain Pan Ho	eater (Electric & KoolGas) (9)
	(120V	
	0387036 (1)	2 Door Models (HE.4850239)
	0387037 (1)	3 Door Models (HE.4850240)
	0387038 (1)	4 Door Models (HE.4850241)
	0387039 (1)	5 Door Models (HE.4850242)
Тамп	ое Ватгаете І	LED FIXTURES AND POWER SUPPLY
J.	0430330	2 Lamp Ballast (BA.4480342)
	0454319	3 Lamp Ballast (BA.4480601)
	0424649	Export Ballast (BA.0424649)
K.		Standard Fluorescent Lamp
		Replace with like fixtures
L.	0499399	LED Power Supply(EP.4481668)

LED Fixture

Replace with like fixtures

INSTALLATION AND SERVICE manual, PIN 0425683, for Innovator II door and frame replacement parts.

Data sheet-Reach-in RL

Note: Revision Q: April 2017. Updated LED energy values. Other changes marked with a bar, circle or underline.

M.

Wiring Item #

Engineering Plan Views

Reach-In

2, 3, 4 & 5 Door

RL - RM - RMF Plan View 06-2009

PHYSICAL DATA

Merchandiser Drip Pipe (in.) 1 1/4
Merchandiser Liquid Line (in.) 3/8
Merchandiser Suction Line (in.) 5/8

(44)

Dimensions shown as in. & (mm). В 4 In (102 MM) REQUIRED AIR GAP 32 6 Skid/ (152) (813) 41 ⁵/8 External Bottom (1057) 48 Base **5** ⁵/8 34 ⁵/8 Front (178) (1219) (879)(143)Waste Outlet Refrigeration Outlet-43 3/4 Electrical Wireway (1111) - Splashguard 4 Relay & Terminal **70** ¹/₄ (102) **Front** Block Location (1784) 1³/4⁻

5-Door Shown

Clearance for Door Swing

26 ¹/₂ (673)

		4.5		2.5	1.5	
		1 Dr	2 Dr	3 Dr	4 Dr	5 Dr
Genera	-	21 1/ (000)	(2 (1575)	02.1/ (22.50)	100 7/ (0101)	152.2/ (2006)
(A)	Case Length (without ends or partitions)	31 1/2 (800)	62 (1575)	92 1/2 (2350)	122 7/8 (3121)	153 3/8 (3896)
	E: Each solid end adds approximately 2 3/8 in (60 mm) to len		n partition add appro	eximately 2 ³ / ₄ in (70) mm);	
case to	case joints can add approximately 1/8 in (3 mm) for gasket n			1		
	Maximum O/S dimension of case back to front	43 3/4 (1111)	43 3/4 (1111)	43 3/4 (1111)	43 3/4 (1111)	43 3/4 (1111)
	(Includes bumper. Add 26 ½ in. (673 mm) for door swing.)					
	Back of case to rear of splashguard	39 7/8 (1013)	39 7/8 (1013)	39 7/8 (1013)	39 7/8 (1013)	39 7/8 (1013)
	Width of Skidrail	3 3/4 (95)	3 3/4 (95)	3 3/4 (95)	3 3/4 (95)	3 3/4 (95)
	Width of Bottom Front Support	6 (152)	6 (152)	6 (152)	6 (152)	6 (152)
	Stub-up area between front support and splashguard	3 1/8 (79)	3 1/8 (79)	3 1/8 (79)	3 1/8 (79)	3 1/8 (79)
Electri	cal Service					
	RH end of case to the center of nearest knockout	4 (102)	4 (102)	4 (102)	4 (102)	4 (102)
	RH end of case to the center of LH knockout	27 1/2 (698)	58 (1473)	88 1/2 (2248)	118 7/8 (3019)	149 3/8 (3794)
	Back O/S of case to center of knockout	41 5/8 (1058)	41 5/8 (1058)	41 5/8 (1058)	41 5/8 (1058)	41 5/8 (1058)
* NOT	E: Electrical Field Wiring Connection Point is at terminal.					
Waste	Outlet ()					
(B)	Right end of case to center of waste outlet	15 3/4 (400)	23 7/8 (606)	54 1/4 (1378)	46 1/4 (1175)	76 5/8 (1946)
	Back O/S of case to center of waste outlet	34 5/8 (879)	34 5/8 (879)	34 5/8 (879)	34 5/8 (879)	34 5/8 (879)
Water	Seal					
	Edge of water seal to center of waste outlet	13 (330)	13 (330)	13 (330)	13 (330)	13 (330)
	Schedule 40 PVC drip pipe	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)
** NOT	TE: Field installed water seal outlets, tees, and connectors are	shipped with case				
Refrige	eration Outlet					
	RH end of case to center of RH refrigeration outlet	5 3/8 (137)	5 3/8 (137)	5 3/8 (137)	5 3/8 (137)	5 3/8 (137)
	Back O/S of case to center of refrigeration outlet	32 (813)	32 (813)	32 (813)	32 (813)	32 (813)
	Outside bottom front supports from end of case	6 3/4 (170)	6 3/4 (170)	6 3/4 (170)	6 3/4 (170)	6 3/4 (170)
	Center bottom front support from Centerline	NA	24 (610)	24 (610)	24 (610)	24 (610)
	Distance between Center and Outside supports will vary					


Reach-in 2, 3, 4 and 5 Door Models



Hussmann refrigerated merchandisers configured for sale for use in the United States meet or surpass the requirements of the DOE 2017 energy efficiency standards.

Standard Reach-in configuration consists of Innovator doors, energy efficient fan motors, and EcoShine II LED vertical lighting.

Dimensions shown as in. & (mm).



Length Added to Lineup by each

Standard End (in.)2Optional End with Window (in.) $1 \frac{1}{2}$ Optional Partition (in.) $1 \frac{1}{2}$

NSF Certification

This merchandiser model is manufactured to meet NSF/ANSI (National Sanitation Foundation) Standard #7 requirements for construction, materials & cleanability.

RL

With INNOVATOR II Doors Frozen Food & Ice Cream

REFRIGERATION DATA§

Note: This data is based on store temperature and humidity that does not exceed 75°F and 55% R.H.

	FF	IC
Discharge Air (°F)	-5	12
Evaporator (°F)	_9	-17
Unit Sizing (°F)	-12	-20
BtulhrlDoor	FF	IC
Parallel	830	900
Conventional	845	920

§ Average evaporator temperature shown. Use dew point for high glide refrigerants for unit sizing. Care should be taken to use the dew point in PT tables for measuring and adjusting superheat. Adjust evaporator pressure as needed to maintain discharge air temperature shown.

DEFROST DATA

	FF	IC
Frequency (hr)	24	24
Defrost Water (lb/Dr/day)	1.2	1.2
(± 15% based on case conf	igura	tion and
product loading.)		

ELECTRIC	FF	IC
Temp Term (°F)	48°	48°
Failsafe (minutes)	45	45
C :-		

GAS

Duration (minutes) 20 20

OFFTIME Not Recommended

CONVENTIONAL CONTROLS

Low Pressure Backup Control

FF IC CI/CO (Temp °F)* -18°/-34° - 26°/-45°

Indoor Unit Only, Pressure Defrost Termination (Temp °F)*

Not Recommended

*Use a Temperature Pressure Chart to determine PSIG conversions.

PHYSICAL DATA

Estimated Charge **

2Dr	1.8 lb	29 oz	0.8 kg
3Dr	2.7 lb	43 oz	1.2 kg
4Dr	3.6 lb	57 oz	1.6 kg
5Dr	4.6 lb	73 oz	2.0 kg

**This is an average for all refrigerant types. Actual refrigerant charge may vary by approximately half a pound (8 oz / 0.2 kg).

RL With INNOVATOR II Doors Frozen Food & Ice Cream

Hussmann recommends against frame heater cycling with *Innovator* doors to prevent door seals from freezing to the frames and tearing.

Electrical Data

	2Dr	3Dr	4Dr	5Dr
Number of Fans—12W	2	3	4	5

				Amp	eres		1	Wa	atts	
Merchand	liser		2Dr	3Dr	4Dr	5Dr	2Dr	3Dr	4Dr	5Dr
F .	E									
Evaporato		G. 1 1E ECC.	0.60	0.00	1.20	1.50	26		72	0.0
120V	60Hz	Standard Energy Efficient	0.60	0.90	1.20	1.50	36	54	72	90
220V	60Hz	Standard Energy Efficient	0.30	0.45	0.60	0.75	36	54	72	90
Door Ant	i-sweat H	eaters (on fan circuit)	NA							
Frame An	ıti-sweat I	Heaters (on fan circuit)								
120V	50/60H	z Standard	0.89	1.34	1.79	2.24	107	161	215	269
220V	50/60H	z Export	0.49	0.73	0.98	1.22	107	161	215	269
Minimum	Circuit A	mnacity								
120V	60Hz	Standard Energy Efficient	1.69	2.44	3.19	3.94				
220V	60Hz	Standard Energy Efficient	0.99	1.38	1.78	2.17				
,	00112	Stundard Energy Enterent	0.55	1.00	11,70	2.17				
Maximun	n Over Cu	rrent Protection 120V	20	20	20	20				
Maximun	n Over Cu	rrent Protection 220V	15	15	15	15				
Defrost										
	Heaters (1	20V)	0.63	1.25	2.00	2.57	75	150	240	300
	t: 220V 50		0.34	0.76	1.22	1.53	84	168	269	336
(2por	, , ,	, 112)	0.5.	0.70	1,	1.00		100	20)	220
208V E	lectric De	efrost	6.72	10.08	13.46	16.82	1400	2100	2800	3500
(Expor	t: 220V 50) Hz)	7.11	10.66	14.24	17.79	1564	2345	3133	3914
Standard	Vertical I	ED Lighting	2Dr	3Dr	4Dr	5Dr	2Dr	3Dr	4Dr	5Dr
		hine II TM - A (120V)	0.31	0.46	0.62	0.77	37.1	55.6	74.2	92.7
		nine II TM - A (220V Export)	0.17	0.25	0.34	0.42	37.1	55.6	74.2	92.7
		· · · · · · · · · · · · · · · · · · ·				~ · · -			,	
-		ED Lighting								
Hussma	ann EcoS	hine II TM - B (120V)	0.36	0.52	0.68	0.84	43.2	62.3	81.4	100.5
Hussma	ann EcoSh	nine II TM - B (220V Export)	0.20	0.28	0.37	0.46	43.2	62.3	81.4	100.5

RL
With INNOVATOR II Doors
Frozen Food & Ice Cream

Product Data

 Recommended Usable Cube 1 (Cu FtlDr)
 23.46 ft³/Dr (0.66 m³/Dr)

 AHRI Total Display Area 2 (Sq FtlDr)
 13.04 ft²/Dr (1.21 m²/Dr)

 Shelf Area 3 (Sq FtlDr)
 29.32 ft²/Dr (2.72 m²/Dr)


³ Shelf surface area is composed of bottom deck plus standard shelf complement, as shown in the Hussmann *Product Reference Guide*. The standard shelf complement for this model is (5) rows of 22-inch shelves.

ESTIMATED SHIPPING WEIGHT 5							
Case						Solid End	
	1 Dr	2 Dr	3 Dr	4 Dr	5 Dr	(each)	
lb (<i>kg</i>)	NA (NA)	997 (453)	1295 (589)	1595 (725)	1874 (852)	55 (25)	

¹ AHRI Refrigerated Volume less shelving and other unusable space: Refrigerated Volume/Unit of Length, ft³/ft [m³/m]

² Computed using AHRI 1200 standard methodology: Total Display Area, ft² [m²]/Unit of Length, ft [m]

Fan and Heater Circuits - Electric Defrost (standard) Low Temperature



Electric Defrost Sequence - Low Temperature

- 1. Power from the defrost contactor energizes Defrost Heaters and 208V Evaporator Fan Relay Coil (7). Relay Contacts open the fan circuit and energizes the Drain Pan Heater.
- 2. If the Defrost Heater raises internal air temperature above 90°F, the Defrost Limit Thermostat (4) will open.
- 3. Temperature rise of the evaporator closes the Relay Control Thermostat (5) at about 35°F, energizing 120V A.S. Relay Coil (6). This relay's contacts open the Frame and Door Heater Circuits.
- 4. When Defrost Termination Thermostat ends defrost period, the defrost contactor opens the Defrost Heater and Evaporator Fan Relay Coil Circuits. The Drain Pan Heater goes off and fans are on.
- 5. Temperature fall of the evaporator opens the Relay Control Thermostat (5) at about 20°F, de-energizing 120V A.S. Relay Coil (6). A.S. Relay Contacts close the Frame and Door Heater Circuits.


Fan and Heater Circuits - Gas Defrost (optional) Low Temperature

CIRCLED NUMBERS = PARTS LIST ITEM NUMBERS

R = Red P = Purple 2P = Purple (2 Bands) DB = Dark Blue BK = Black

LB = Light Blue BR = Brown Y = Yellow OR = Orange W = White

THESE ARE MARKER COLORS (WIRE MAY VARY.)



Gas Defrost Sequence - Low Temperature

- 1. Defrost vapor enters evaporator causing a rise in temperature. At about 35°F the Control Relay Thermostat (5) closes the Fan Relay Coil (7) and Control Relay Coil (6) circuit. The Coil opens the Fan, Door Heater, and Frame Heater circuits, while energizing the Drain Pan Heater (9).
- 2. If the Drain Pan Heater (9) raises internal air temperature above 90°F, the Heater Limit Thermostat (4) will open.
- 3. When the defrost timer ends a defrost period, the evaporator temperature will start to fall. At about 20°F, the Control Relay Thermostat will open, de-energizing the Control Relay Coil and Fan Relay Coil (7). Control and Fan Relay's will open the Drain Pan Heater circuits, and will close the Fan, Door Heater, and Frame Heater circuits.