

Portion of parts removed for clarity.

8 foot merchandiser shown.

NSF Certification

This merchandiser model is manufactured to meet NSF/ANSI (National Sanitation Foundation) Standard #7 requirements for construction, materials and cleanability.

Performance Data Product Data (AHRI Statistics) Cross Section Plan View Electrical Loads Page 2Estimated Shipping WeightsPage 6Page 2Shelf OptionsPage 6Page 3Wiring DiagramsPage 7Page 4Computing Refrigeration and Electrical LoadPage 10Page 5Revision HistoryPage 10

Data sheet-Insight IP4NL

We reserve the right to change or revise specifications and product design in connection with any feature of our products. Such changes do not entitle the buyer to corresponding changes, improvements, additions or replacements for equipment previously sold or shipped.

	IP4NL		Optimal Shelf Life				
	Application	Cut Produce	Bulk Produce	NSF Type 2 Ambient⁴	AHRI 1200 Rating Point⁵		
Unlit Shelves	Discharge Air °F (°C)	35 (1.66)	42 (5.55)	31 (-0.55)	35 (1.66)		
	Average Evaporator °F (°C) ^{2,3}	29 (-1.66)	37 (2.77)	27 (-2.77)	29 (-1.66)		
	Parallel Btu/hr/ft (Watts/m)	1100 (1058)	798 (767)	1398 (1344)	1100 (1058)		
	Conventional Btu/hr/ft (Watts/m)	1200 (1154)	870 (837)	1525 (1466)	1200 (1154)		
	Discharge Air °F (°C)	34 (1.11)	41 (5.55)	30 (-1.11)	34 (1.11)		
Lit	Average Evaporator °F (°C) ^{2,3}	28 (-2.22)	36 (2.77)	26 (-3.33)	28 (-2.22)		
Shelves	Parallel Btu/hr/ft (Watts/m) ⁶	1114 (1071)	807 (776)	1416 (1362)	1114 (1071)		
	Conventional Btu/hr/ft (Watts/m) 6	1215 (1168)	880 (846)	1545 (1486)	1215 (1168)		
Tan Croad ⁷	IP4NL6 (8.25")	14007	14007	1600 ⁷	1400 ⁷		
Fan Speed ⁷	IP4NL4, 8, 12 (10.3")	1050	1050	1300 ⁷	1050		

Notes:

1. All data based on store temperature and humidity that does not exceed NSF Type 1 ambient conditions of 75°F and 55% relative humidity except where noted.

2. Average evaporator temperature shown. Use dew point for high glide refrigerants for unit sizing. Care should be taken to use the dew point in PT tables for measuring and adjusting superheat. Adjust evaporator pressure as needed to maintain discharge air temperature shown.

3. For DX CO₂ applications the average evaporator temperature may be lowered by 2°F but not more than 5°F. An EPR valve should be used if the system suction temperature is more than 5 degrees below the published case evaporator temperature. A 31°F flash tank temperature with a 24°F evaporator temperature is used when sizing default EEV selections to provide a minimum pressure drop across the valve of approximately 50 psig. For operating conditions that provide a pressure drop across the valve above 65 psig or below 35 psig, the electronic expansion valve size should be determined using the valve vendor sizing program and selected from the pull down list in the Hussmann Product Configurator (HPC).

4. Data for operation in NSF Type 2 ambient of 80°F and 55% relative humidity.

5. AHRI 1200 Rating Point for energy consumption comparison only.

6. Add 10 Btu/hr/ft (9.6 Watts/m) per shelf row for LED shelf light fixtures.

7. Some lengths and/or applications require optional fan motor kits applied by the Hussmann Product Configurator (HPC).

Defrost Data — Cu	It Product	Conventional Controls	Estimated Charge ¹⁰			IP4NL	
Frequency (hours between defrost) 4		IP4NL	4 ft	0.6 lb	10 oz	0.3 kg	
	,	Low Pressure Backup	6 ft	1.1 lb	18 oz	0.5 kg	
OFFTIME	IP4NL	Control CI/CO ⁹	8 ft	1.5 lb	24 oz	0.7 kg	
Time (minutes)	20	20°F / 10°F –6.67°C / –12.2°C	12 ft	2.9 lb	46 oz	1.3 kg	
ELECTRIC OR GAS	Not Available						
		Indoor Unit Only,		s an average		, ,,	
Defrost Water ⁸	7.8 lb/ft/day	Pressure Defrost		0	0 ,	ry by approx-	
	(11.6 kg/m)	Termination ⁹	imately	half a pound.			
⁸ (± 15% based on case configuration and product		48°F (8.89°C)					
loading).		⁹ Use a Temperature Pressure Chart to determine PSIG conversions.					

Product Data

Gross Refrigerated Volume ¹¹ (Cu Ft/Ft) AHRI Total Display Area ¹² (Sq Ft/Ft) Shelf Area ¹³ (Sq Ft/Ft) 7.85 ft³/ft (0.73 m³/m) 3.94 ft²/ft (1.20 m²/m) 5.94 ft²/ft (1.81 m²/m)


¹¹ AHRI Gross Refrigerated Volume: Refrigerated Volume/Unit of Length, ft³/ft [m³/m]

- ¹² Computed using AHRI 1200 standard methodology: Total Display Area, ft² [m²]/Unit of Length, ft [m]
- ¹³ Shelf surface area is composed of bottom deck plus standard shelf complement for this model: (3) rows of shelves: 14-in., 16-in., 16-in.

Insight Multideck Merchandiser, 4 Display Levels, Narrow Bottom, Low Height Front

DOE 2017 Energy Efficiency Compliant

Hussmann refrigerated merchandisers configured for sale for use in the United States meet or surpass the requirements of the DOE 2017 energy efficiency standards.




to meet NSF/ANSI (National Sanitation Foundation) Standard #7 requirements for construction, materials and cleanability.

Engineering Plan View

IP4NL

Dimensions shown as in. and (mm).



FRONT

(12 Foot Model shown above)

		4 ft	6 ft	8 ft	12 ft
Gene	ral				
(A)	Case Length (without ends or partitions) (Each end and insulated partition adds $1^{1/2}$ in. (38 mm) to case line up.)	48 1/8 (1222)	72 1/4 (1835)	96 1/4 (2445)	144 3/8 (3668)
	Maximum O/S dimension of case back to front (includes bumper)	38 5/8 (981)	38 5/8 (981)	38 5/8 (981)	38 5/8 (981)
	Back of case to front of splashguard	30 5/8 (778)	30 5/8 (778)	30 5/8 (778)	30 ⁵ /8 (778)
(B)	Distance between edges of external legs and center legs	NA	29 (737)	41 (1041)	41 (1041)
(C)	Distance between edges of center legs	41 1/8 (1045)	NA	NA	41 1/8 (1045)
	Distance between front legs and splashguard	3 1/4 (83)	3 1/4 (83)	3 1/4 (83)	3 ¹ / ₄ (83)
Elect	rical Service (Field Electrical Wiring Connection)				
(D)	RH End of case to center of Field Electrical Wiring Connection (top of case)	39 ³ / ₈ (1000)	63 ¹ / ₂ (1613)	87 ¹ / ₂ (2223)	135 1/2 (3442)
	Back of case to center of Field Electrical Wiring Connection	11 1/8 (283)	11 1/8 (283)	11 1/8 (283)	11 1/8 (283)
	Length of electrical wireway	44 5/8 (1133)	33 ¹ / ₂ (851)	45 7/8 (1191)	45 7/8 (1191)
(E)	RH end of case to LH end of electrical wireway (top of case)	46 1/2 (1181)	70 ¹ / ₂ (1791)	94 1/2 (2400)	142 5/8 (3623)
Wast	e Outlets				
(F)	RH End of case to the center of waste outlet	24 1/8 (613)	24 1/8 (613)	24 1/8 (613)	72 1/4 (1835)
	Back O/S of case to center of waste outlet(s)	28 5/8 (727)	28 5/8 (727)	28 5/8 (727)	28 5/8 (727)
	Schedule 40 PVC drip pipe	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)
Refri	geration Shroud				
(G)	Back of case to center of refrigeration shroud *6 foot case at 42° angle parallel to the plenum	22 7/8 (581)	21 1/8 (537)*	22 7/8 (581)	22 7/8 (581)
	End of case to center of refrigeration shroud	9 1/2 (241)	7 5/8 (194)	9 ¹ / ₂ (241)	9 1/2 (241)

Electrical Data

			4 ft	6 ft	8 ft	12 ft				
Number	of Fans									
8.25-in	1.		-	2	-	-				
10.3-in	1.		1	-	2	3				
				Amp	eres			Wa	itts	
Evapora	tor Fan		4 ft	6 ft	8 ft	12 ft	4 ft	6 ft	8 ft	12 ft
120V	60Hz	Energy Efficient	0.40	0.60	0.80	1.20	24	36	48	72
230V		Energy Efficient	0.21	0.31	0.42	0.62	24	36	48	72
Minimur	n Circuit A	Ampacity								
120V	60Hz	Energy Efficient	0.60	0.80	1.00	1.40				
230V	50/60Hz	Energy Efficient	0.41	0.51	0.62	0.82				
Maximum Over Current Protection 120V			20	20	20	20				
Maximum Over Current Protection 230V			15	15	15	15				

Lighting

ONLY LIGHTING CONFIGURATIONS THAT ARE COMPLIANT WITH THE U.S. DEPT. OF ENERGY (DOE) 2017 REGULATION ARE AVAILABLE FOR SALE FOR USE IN THE U.S.A.

		Amp	eres			Wa	itts	
	4 ft	6 ft	8 ft	12 ft	4 ft	6 ft	8 ft	12 ft
LED LIGHTING								
Standard LED Canopy Lights								
1 Row LED Canopy (Standard)	0.16	0.22	0.31	0.47	19	27	38	57
Optional LED Shelf Lights								
1 Row of Shelves	0.06	0.07	0.11	0.17	7	9	13	20
2 Rows of Shelves	0.11	0.15	0.22	0.33	13	18	27	40
3 Rows of Shelves	0.17	0.22	0.33	0.50	20	27	40	60
4 Rows of Shelves	0.22	0.30	0.44	0.67	27	36	53	80
5 Rows of Shelves	0.28	0.37	0.56	0.83	33	44	67	100
Rail Light-1 Row	0.06	0.07	0.11	0.17	7	9	13	20

120V Lighting Circuit Total = Standard Lighting + Total Optional Lighting + Optional Shelf Lighting 230V Lighting Circuit Total = Multiply 120V Lighting Circuit Total by 0.52

ENDS or PARTITIONS

Each standard end and each insulated partition adds 1 ¹/₂ in. (38 mm) to case line up. Optional view end with end bumper adds 3 ³/₄ in. (95 mm).

PHYSICAL DATA

Merchandiser Drip Pipe (in.)1 1/4Schedule 40 PVCMerchandiser Liquid Line (in.)3/8Merchandiser Suction Line (in.)5/8

ESTIMATED SHIPPING WEIGHT †							
Case					Solid End		
	4 ft	6 ft	8 ft	12 ft	(each)		
lb (kg)	700 (318)	850 (386)	950 (431)	1200 (544)	70 (32)		
† Actual weights will vary according to optional kits included.							

Shelf Options

Approved shelf sizes for standard (horizontal, 2-3 position brackets) displays:

14-inch 16-inch 18-inch

Contact engineering for non-standard (4 position brackets or other) display recommendations.


Minimum number of Shelves: 1 (for bulk produce)

Optimal number of Shelves: 3

Maximum number of Shelves: 6

Maximum number of Lighted Shelves: 5


Standard shelf complement for test purposes: (3) rows of shelves (14-in., 16-in., 16-in.), spacing between each row of shelves is 12-in., all vertical with a 16-in. mirror installed in the top, rear corner of the case.




LED Canopy Light Circuits

LED Canopy Lighting - 1 Row

P/N 0551268 J






Optional Shelf Harness and LED Light Circuits for 2 or 3 Rows of Shelves

WARNING

All components must have mechanical ground, and the merchandiser must be grounded.

R = Red	Y = Yellow	G = Green	BL = Blue	BK = B	lack W = White	
• = 120V Pov	ver o= ²	20V NEUTRAL	∔ = Field C	GROUND	mm = CASE GROUND	



Optional Shelf Harness and LED Light Circuits for 4 or 5 Rows of Shelves

WARNING

All components must have mechanical ground, and the merchandiser must be grounded.

R = Red	Y = Yellow	G = Green	BL = Blue	BK = Black	W = White
• = 120V Pov	ver 0 = 12	20V NEUTRAL	± = Field G	ROUND mm :	CASE GROUND

Insight **IP4NL** Cut and Bulk Produce

Estimating Refrigeration and Electrical Load (for comparison purposes only)

Case Btu

To determine Btu for a case, refer to the performance data chart on page 2. Select lit or unlit shelves, then select the type of remote refrigeration system (parallel or conventional), which will give Btu/hr/ft. Multiply this number by the length of the case to determine Btu per hour. Add 10 BTU/HR/FT for each row of LED shelf lights.

Case Electrical

Refer to store legend to determine number of circuits. Lighting should be specified in store legend.

Fan electrical load for a case is computed by selecting the case length and fan voltage on page 6. For example, a 12 ft case uses 3 fans. The store legend specifies fans on a 230V circuit. In this instance, fans use 0.62 Amps and the MCA is 0.82. When applied, ambient fans, anti-sweat heaters, controllers, etc. must be included in the MCA. Include lights in the MCA if lights are on same circuit.

Lights may be on a separate circuit. To estimate lighting load: select case length (12 ft), canopy lighting [standard or optional] (here 0.70 for standard), and shelf or rail lighting [maximum for which case is wired] (1.24 for five shelves); then add together [0.48 + 1.24 = 1.72 amps for 120V] (for 230V, multiply $1.72 \times 0.52 = 0.89$).

Line Sizing — Refer to store legend.

Hussmann Line Sizing Charts are engineered for use with Hussmann refrigeration equipment.



Scan the QR code with your mobile device to access additional product information or order parts.

Parts may also be ordered at: parts.hussmann.com Call toll free: 1.855.487.7778

Revision History

Revision A: November 2016: Original Issue

- Revision B: January 2017: Added rail light updates.
- Revision C: March 2017: Updated eletrical data.
- Revision D: April 2017: Updated LED energy values.
- Revision E: April 2017: Updated LED energy values.
- Revision F: September 2017: Updated notes page.
- Revision G: February 2018: Updated cross section.

Revision H: January 2023: Added CO₂ note, Page 2.

Revision J: December 2023: Updated fan and lighting information. Removed replacement parts page. Updated wiring diagrams.