HUSSMANN

Insight® IC4BM

Dairy / Delicatessen / Meat / Produce


Merchandiser Data Sheet

P/N 3016850_G

NSF® Certified

December 2023

Insight standard field electrical connections are at the top of the merchandiser



DOE 2017
Energy Efficiency
Compliant





NSF Certification

12 foot merchandiser shown.

This merchandiser model is manufactured to meet NSF/ANSI (National Sanitation Foundation) Standard #7 requirements for construction, materials and cleanability.

Performance Data	Page 2	Estimated Shipping Weights	Page 6
Product Data (AHRI Statistics)	Page 2	Shelf Options	Page 6
Cross Section	Page 3	Wiring Diagrams	Page 7
Plan View	Page 4	Computing Refrigeration and Electrical Load	Page 9
Electrical Loads	Page 5	Revision History	Page 9

Data sheet-Insight IC4BM

We reserve the right to change or revise specifications and product design in connection with any feature of our products. Such changes do not entitle the buyer to corresponding changes, improvements, additions or replacements for equipment previously sold or shipped.

Refrigeration Data¹

	IC4BM	Optimal Shelf Life				Energy Comparison	
Application		Dairy/Deli/ Beverage/ Produce	Convertible/ Meat	NSF Type 2 Ambient ⁴	Bulk Produce	AHRI 1200 Rating Point ⁵	
	Discharge Air °F (°C)	32 (0)	32 (0)	30 (-1.11)	42 (5.55)	36 (2.22)	
Unlit Shelves	Average Evaporator °F (°C) ²	28 (-2.22)	27 (-2.77)	26 (-3.33)	37 (2.77)	31 (-0.55)	
	Parallel Btu/hr/ft (Watts/m)	834 (802)	862 (829)	1036 (996)	642 (617)	733 (705)	
	Conventional Btu/hr/ft (Watts/m)	910 (875)	940 (904)	1130 (1087)	700 (673)	800 (769)	
	Discharge Air °F (°C)	31 (-0.55)	31 (-0.55)	29 (-1.66)	41 (5.0)	35 (1.66)	
Lit	Average Evaporator °F (°C) ²	27 (-2.77)	26 (-3.33)	25 (-3.88)	36 (2.22)	31 (-0.55)	
Shelves	Parallel Btu/hr/ft (Watts/m) ⁶	857 (824)	875 (842)	1045 (1005)	651 (626)	743 (714)	
	Conventional Btu/hr/ft (Watts/m) ⁶	935 (899)	955 (918)	1140 (1096)	710 (683)	810 (779)	
Fan Spood?	IC4BM6 (8.25")	1300	1300	1500 ⁷	1300	1300	
Fan Speed ⁷	IC4BM4, 8, 12 (8.25")	1300	1300	1500 ⁷	1300	1300	

Notes

- 1. All data based on store temperature and humidity that does not exceed NSF Type 1 ambient conditions of 75°F and 55% relative humidity except where noted
- Average evaporator temperature shown. Use dew point for high glide refrigerants for unit sizing. Care should be taken to use the dew point in PT tables for measuring and adjusting superheat. Adjust evaporator pressure as needed to maintain discharge air temperature shown.
- 3. For DX CO₂ applications the average evaporator temperature may be lowered by 2°F but not more than 5°F. An EPR valve should be used if the system suction temperature is more than 5 degrees below the published case evaporator temperature. A 31°F flash tank temperature with a 24°F evaporator temperature is used when sizing default EEV selections to provide a minimum pressure drop across the valve of approximately 50 psig. For operating conditions that provide a pressure drop across the valve above 65 psig or below 35 psig, the electronic expansion valve size should be determined using the valve vendor sizing program and selected from the pull down list in the Hussmann Product Configurator (HPC).
- 4. Data for operation in NSF Type 2 ambient of 80°F and 55% relative humidity.
 5. AHRI 1200 Rating Point for energy consumption comparison only.
 6. Add 10 Btu/hr/ft (9.6 Watts/m) per shelf row for LED shelf light fixtures.
- Some lengths and/or applications require optional fan motor kits applied by the Hussmann Product Configurator (HPC).

Defrost Data

Frequency (hours between defrost) Defrost Water 8 8.1 lb/ft/day (12 kg/m)

8 (± 15% based on case configuration and product loading).

IC4BM **O**FFTIME Time (minutes) 20

ELECTRIC OR GAS Not Available

Conventional Controls

IC4BM

Low Pressure Backup Control CI/CO 9

> 20°F /10°F -6.7°C / -12.2°C

Indoor Unit Only, Pressure Defrost Termination⁸

48°F (8.9°C)

Estim	ated Charge	10	IC4BM
4 ft	0.6 lb	10 oz	0.3 kg
6 ft	1.1 lb	18 oz	0.5 kg
8 ft	1.5 lb	24 oz	0.7 kg
12 ft	2.9 lb	46 oz	1.3 kg

¹⁰ This is an average for all refrigerant types. Actual refrigerant charge may vary by approximately half a pound.

Product Data

Gross Refrigerated Volume 11 (Cu Ft/Ft) 10.9 ft³/ft (1.01 m³/m) AHRI Total Display Area 12 (Sq Ft/Ft) 3.65 ft²/ft (1.11 m²/m) Shelf Area 13 (Sq Ft/Ft) 8.34 ft²/ft (2.54 m²/m)

⁹ Use a Temperature Pressure Chart to determine PSIG conversions

¹¹ AHRI Gross Refrigerated Volume: Refrigerated Volume/Unit of Length, ft³/ft [m³/m]

¹² Computed using AHRI 1200 standard methodology: Total Display Area, ft² [m²]/Unit of Length, ft [m]

¹³ Shelf surface area is composed of bottom deck plus standard shelf complement for this model: (3) rows of 22-in. shelves

DOE 2017
Energy Efficiency
Compliant


Hussmann refrigerated merchandisers configured for sale for use in the United States meet or surpass the requirements of the DOE 2017 energy efficiency standards.

Dimensions shown as in. and (mm).

Shelf complement shown as tested:


Three rows of shelves 22-in. shelves spaced equally between bottom display pan and interior top panel.

OPTIONAL RAIL LIGHT



Rail light cannot be used with glass front option.

OPTIONAL GLASS FRONT



Glass front cannot be used with rail light option.

1 1/2 In. (38 mm) Required IC4BM Air Gap 43 7/8 (1114)9 1/4 (235) ▼ **83** 1/4 (2115)**53** 3/8 **43** 7/8 (1114) (1356)0 **34** 1/8 (867)**29** 5/8 **25** 3/4 (652)**12** 1/8 (308)32 7/8 (835) **37** 1/2 (953)**39** 1/2 (1003)47 1/2 (1207)


NSF Certification

This merchandiser model is manufactured to meet NSF/ANSI (National Sanitation Foundation) Standard #7 requirements for construction, materials and cleanability.

Engineering Plan View

IC4BM

Dimensions shown as in. and (mm).



(12 Foot Model shown above)

		4 ft	6 ft	8 ft	12 ft
Gene	ral				
(A)	Case Length (without ends or partitions) (Each end and insulated partition adds $1^{-1/2}$ in. (38 mm) to case line up.)	48 1/8 (1222)	72 1/4 (1835)	96 1/4 (2445)	144 3/8 (3668)
	Maximum O/S dimension of case back to front (includes bumper)	47 1/2 (1206)	47 1/2 (1206)	47 1/2 (1206)	47 1/2 (1206)
	Back of case to front of splashguard	39 1/2 (1003)	39 1/2 (1003)	39 1/2 (1003)	39 1/2 (1003)
(B)	Distance between edges of external legs and center legs	NA	29 (737)	41 (1041)	41 (1041)
(C)	Distance between edges of center legs	41 1/8 (1045)	NA	NA	41 1/8 (1045)
	Distance between front legs and splashguard	8 (203)	8 (203)	8 (203)	8 (203)
Elect	rical Service (Field Electrical Wiring Connection)				
(D)	RH End of case to center of Field Electrical Wiring Connection (top of case)	39 3/8 (1000)	63 1/2 (1613)	87 1/2 (2223)	135 1/2 (3442)
	Back of case to center of Field Electrical Wiring Connection	18 1/2 (470)	18 1/2 (470)	18 1/2 (470)	18 1/2 (470)
	Length of electrical wireway (canopy)	44 5/8 (1133)	33 1/2 (851)	45 7/8 (1165)	45 ⁷ /8 (1165)
(E)	RH end of case to LH end of electrical wireway (canopy)	46 1/2 (1181)	70 1/2 (1791)	94 1/2 (2400)	142 5/8 (3630)
Wast	e Outlets				
(F)	RH End of case to the center of waste outlet	24 1/8 (613)	24 1/8 (613)	24 1/8 (613)	72 1/4 (1835)
	Back O/S of case to center of waste outlet(s)	37 3/8 (950)	37 3/8 (950)	37 3/8 (950)	37 3/8 (950)
	Schedule 40 PVC drip pipe	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)
Refri	geration Outlet				
(G)	Back of case to center of refrigeration outlet	32 7/8 (835)	32 7/8 (835)	32 7/8 (835)	32 7/8 (835)
	End of case to center of refrigeration outlet	8 1/2 (216)	8 1/2 (216)	8 1/2 (216)	8 1/2 (216)

Electrical Data

Number	of Fans		4 ft	6 ft	8 ft	12 ft				
8.25-in			1	2	2	3				
				Amp	eres			Wa	itts	
Evapora	tor Fan		4 ft	6 ft	8 ft	12 ft	4 ft	6 ft	8 ft	12 ft
120V	60Hz	Energy Efficient	0.25	0.50	0.50	0.75	16	32	32	48
230V	50/60Hz	Energy Efficient	0.13	0.26	0.26	0.39	16	32	32	48
Minimun	n Circuit A	ampacity								
120V	60Hz	Energy Efficient	0.45	0.70	0.70	0.95				
230V	50/60Hz	Energy Efficient	0.33	0.46	0.46	0.59				
Maximur	m Over Cu	rrent Protection								
120V			20	20	20	20				
230V			15	15	15	15				

Lighting

ONLY LIGHTING CONFIGURATIONS THAT ARE COMPLIANT WITH THE U.S. DEPT. OF ENERGY (DOE) 2017 REGULATION ARE AVAILABLE FOR SALE FOR USE IN THE U.S.A.

	Amperes			Watts				
	4 ft	6 ft	8 ft	12 ft	4 ft	6 ft	8 ft	12 ft
LED Lighting								
Standard LED Canopy Lights								
1 Row	0.16	0.22	0.31	0.47	19	27	38	57
Optional LED Shelf Lights								
1 Row of Shelves	0.06	0.07	0.11	0.17	7	9	13	20
2 Rows of Shelves	0.11	0.15	0.22	0.33	13	18	27	40
3 Rows of Shelves	0.17	0.22	0.33	0.50	20	27	40	60
4 Rows of Shelves	0.22	0.30	0.44	0.67	27	36	53	80
5 Rows of Shelves	0.28	0.37	0.56	0.83	33	44	67	100
LED Rail Light								
1 Row	0.06	0.07	0.11	0.17	7	9	13	20

120V Lighting Circuit Total = Standard Lighting + Total Optional Lighting + Optional Shelf Lighting 230V Lighting Circuit Total = Multiply 120V Lighting Circuit Total by 0.52

FNDS or PART	

Each standard end and each insulated partition adds 1 $^{1}/_{2}$ in. (38 mm) to case line up. Optional view end with end bumper adds 3 $^{3}/_{4}$ in. (95 mm).

PHYSICAL DATA

Merchandiser Drip Pipe (in.) 1 1/4
Schedule 40 PVC
Merchandiser Liquid Line (in.) 3/8
Merchandiser Suction Line (in.) 5/8

ESTIMATED SHIPPING WEIGHT †

Case					Solid End
	4 ft	6 ft	8 ft	12 ft	(each)
lb (kg)	700 (318)	850 (386)	1000 (454)	1200 (544)	80 (36)

† Actual weights will vary according to optional kits included.

Shelf Options

Approved shelf sizes for standard (horizontal, 2-3 position brackets) displays:

18-inch

20-inch

22-inch

24-inch

Contact engineering for non-standard (4 position brackets or other) display recommendations.

Minimum number of Shelves: 2


Optimal number of Shelves: 3

Maximum number of Shelves: 5

Maximum number of Lighted Shelves: 5


Standard shelf complement for test purposes: (3) rows of shelves 22-in. shelves evenly distributed vertically.

Fan Wiring Offtime Defrost



LED Canopy Light Circuits

LED Canopy Lighting - 1 Row




All components must have mechanical ground, and the merchandiser must be grounded.

R = Red Y = Yellow G = Green BL = Blue BK = Black W = White \bullet = 120V Power \circ = 120V Neutral \bot = Field Ground $\stackrel{\text{min}}{\longrightarrow}$ = Case Ground

Optional LED Shelf Lighting

Optional Shelf Harness and LED Light Circuits for 4 or 5 Rows of Shelves



WARNING

All components must have mechanical ground, and the merchandiser must be grounded.

R = Red Y = Yellow G = Green BL = Blue BK = Black W = White
$$\bullet$$
 = 120V Power \circ = 120V Neutral $\frac{1}{2}$ = Field Ground $\stackrel{\text{min}}{\text{min}}$ = Case Ground

Estimating Refrigeration and Electrical Load (for comparison purposes only)

Case Btu

To determine Btu for a case, refer to the performance data chart on page 2. Select lit or unlit shelves, then select the type of remote refrigeration system (parallel or conventional), which will give Btu/hr/ft. Multiply this number by the length of the case to determine Btu per hour. Add 10 BTU per foot per hour for each row of LED shelf lights.

Case Electrical

Refer to store legend to determine number of circuits. Lighting should be specified in store legend.

Fan electrical load for a case is computed by selecting the case length and fan voltage on page 6. For example, a 12 ft case uses 3 fans. The store legend specifies fans on a 230V circuit. In this instance, fans use 0.39 Amps and the MCA is 0.59. When applied, ambient fans, anti-sweat heaters, controllers, etc. must be included in the MCA. Include lights in the MCA if lights are on same circuit.

Lights may be on a separate circuit. To estimate lighting load: select case length (12 ft), canopy lighting [standard or optional] (here 0.70 for standard), and shelf or rail lighting [maximum for which case is wired] (1.24 for five shelves); then add together [0.48 + 1.24 = 1.72 amps for 120V] (for 230V, multiply 1.72 * 0.52 = 0.89).

Line Sizing — Refer to store legend.

Hussmann Line Sizing Charts are engineered for use with Hussmann refrigeration equipment.



Scan the QR code with your mobile device to access additional product information or order parts.

Parts may also be ordered at:

parts.hussmann.com Call toll free: 1.855.487.7778

Revision History

Revision A: November 2016: Original Issue

Revision B: January 2017: Updated cross section.

Revision C: April 2017. Updated LED energy values.

Revision D: April 2017. Updated LED energy values.

Revision E: September 2017. Updated notes page. Other changes marked with a bar, circle or underline.

Revision F: January 2023. Added CO2 note, Page 2.

Revision G: December 2023. Updated fan and lighting information. Removed replacement parts page. Updated wiring diagrams.