

*Coils, fans and TXVs are modular with one per 3 or 4 foot section.

Portion of parts removed for clarity.

12 foot merchandiser shown.

NSF Certification

This merchandiser model is manufactured to meet NSF/ANSI (National Sanitation Foundation) Standard #7 requirements for construction, materials and cleanability.

Performance Data Product Data (AHRI Statistics) Cross Section Plan View Electrical Loads

Estimated Shipping Weights Shelf Options Replacement Parts List Wiring Diagrams Computing Refrigeration and Electrical Load Revision History	Page 6 Page 6 Page 7 Page 8 Page 10 Page 10
Revision History	Page 10
	Shelf Options Replacement Parts List Wiring Diagrams Computing Refrigeration and Electrical Load

Data sheet-Insight IC2SM

We reserve the right to change or revise specifications and product design in connection with any feature of our products. Such changes do not entitle the buyer to corresponding changes, improvements, additions or replacements for equipment previously sold or shipped.

IC2SM			Optimal Shelf Life				
	Application	Dairy/Deli/ Beverage/ Produce	Convertible / Meat	NSF Type 2 Ambient ³	AHRI 1200 Rating Point⁴		
	Discharge Air °F (°C)	32 (0)	31 (-0.55)	30 (-1.11)	34 (1.11)		
Unlit Shelves	Average Evaporator °F (°C) ²	28 (-2.22)	27 (-2.77)	26 (-3.33)	30 (-1.11)		
	Parallel Btu/hr/ft (Watts/m) ^₅	665 (640)	705 (678)	765 (736)	620 (596)		
	Conventional Btu/hr/ft (Watts/m) 5	725 (697)	770 (741)	830 (798)	675 (649)		
	Discharge Air °F (°C)	31 (-0.55)	30 (-1.11)	29 (-1.66)	33 (0.55)		
Lit	Average Evaporator °F (°C) ²	27 (-2.77)	26 (-3.33)	25 (-3.88)	29 (-1.66)		
Shelves	Parallel Btu/hr/ft (Watts/m) 5,6	680 (654)	720 (693)	775 (745)	630 (606)		
	Conventional Btu/hr/ft (Watts/m) ^{5, 6}	740 (712)	785 (755)	835 (803)	685 (659)		
Fan Enged ⁷	IC2SM6 (7.0")	1600	1700 ⁷	1700 ⁷	1600		
Fan Speed ⁷	IC2SM4, 8, 12 (7.0")	1600	1700 ⁷	1700 ⁷	1600		

Notes:

1. All data based on store temperature and humidity that does not exceed NSF Type 1 ambient conditions of 75°F and 55% relative humidity except where noted.

2. Average evaporator temperature shown. Use dew point for high glide refrigerants for unit sizing. Care should be taken to use the dew point in PT tables for measuring and adjusting superheat. Adjust evaporator pressure as needed to maintain discharge air temperature shown.

3. Data for operation in NSF Type 2 ambient of 80°F and 55% relative humidity.

4. AHRI 1200 Rating Point for energy consumption comparison only.

5. Subtract 120 Btu/hr/ft (115.4 Watts/m) for front glass (on applicable models).

6. Add 10 Btu/hr/ft (9.6 Watts/m) per shelf row for LED shelf light fixtures.

7. Some lengths and/or applications require optional fan speed control kits applied by the Hussmann Product Configurator.

Defrost Data		Conventional Controls	Estimated Charge ¹⁰ IC2			IC2SM
Frequency (hours between defrost) 4		IC2SM	4 ft	0.6 lb	9.6 oz	0.3 kg
Defrost Water 8	4.2 lb/ft/day	Low Pressure Backup	6 ft	1.1 lb	17.6 oz	0.5 kg
	(6.3 kg/m)	Control CI/CO ⁹	8 ft	1.5 lb	24 oz	0.7 kg
⁸ (± 15% based on case loading).	configuration and product	20°F /10°F –6.7°C / –12.2°C	12 ft	2.9 lb	46.4 oz	1.3 kg
OFFTIME Time (minutes) Electric or Gas	IC2SM 20 Not Available	Indoor Unit Only, Pressure Defrost Termination ⁹ 48°F (8.9°C)	¹⁰ This is an average for all refrigeran Actual refrigerant charge may vary by imately half a pound.		· · ·	
		⁹ Use a Temperature Pressure Chart to determine PSIG conversions.				
Product Data						
Gross Refrigerated Volume ¹¹ (Cu Ft/Ft)		4.2 ft ³ /ft (0.39 m ³ /m)				
AHRI Total Displa	y Area ¹² (Sq Ft/Ft)	2.46 ft²/ft (0.75 m²/m)				
Shelf Area ¹³ (Sq F	t/Ft)	5.04 ft²/ft (1.54 m²/m)				

¹¹ AHRI Gross Refrigerated Volume: Refrigerated Volume/Unit of Length, ft³/ft [m³/m]

¹² Computed using AHRI 1200 standard methodology: Total Display Area, ft² [m²]/Unit of Length, ft [m]

¹³ Shelf surface area is composed of bottom deck plus standard shelf complement for this model:(2) rows of shelves: 12-in., 18-in.

Insight Multideck Merchandiser, Convertible, 2 Display Levels, Standard Bottom, Medium Height Front

DOE 2017 Energy Efficiency Compliant

Hussmann refrigerated merchandisers configured for sale for use in the United States meet or surpass the requirements of the DOE 2017 energy efficiency standards.

Dimensions shown as in. and (mm).

3-in. between back to back IC2SM cases. 1 1/2 In. (38 mm) Required Shelf complement shown as tested: Air Gap Two rows of shelves (12 in., 18 in.) spaced equally between bottom 5 21 7/8 display pan and interior top panel. (127) (556)**OPTIONAL RAIL LIGHT 29** 1/2 (749) 27 7/8 **50** 3/8 (708)(1280) С W 0 Α 30 1/8 L I (765) L Rail light cannot be used 23 with glass front option. FANS (584) **OPTIONAL GLASS FRONT** 19 (483) 7 1/4 (184) 51/2 29 7/8 (140) (759) **34**1/4 (870) 36 3/8 (924) 44 3/8 Glass front cannot be used (1127)with rail light option.

NSF Certification


This merchandiser model is manufactured to meet NSF/ANSI (National Sanitation Foundation) Standard #7 requirements for construction, materials and cleanability.

P/N 0541503_L HUSSMANN CORPORATION • BRIDGETON, MO 63044-2483 U.S.A. • WWW.HUSSMANN.COM 3 of 10

Engineering Plan View

4 of 10

Dimensions shown as in. and (mm).



(12 Foot Model shown above)

		4 ft	6 ft	8 ft	12 ft
Gene	ral				
(A)	Case Length (without ends or partitions) (Each end and insulated partition adds $1^{1/2}$ in. (38 mm) to case line up.)	48 1/8 (1222)	72 1/4(1835)	96 ¹ / ₄ (2445)	144 3/8 (3668)
	Maximum O/S dimension of case back to front (includes bumper)	44 3/8 (1127)	44 3/8 (1127)	44 3/8 (1127)	44 3/8 (1127)
	Back of case to front of splashguard	36 3/8 (924)	36 3/8 (924)	36 3/8 (924)	36 3/8 (924)
(B)	Distance between edges of external legs and center legs	NA	29 (737)	41 (1041)	41 (1041)
(C)	Distance between edges of center legs	41 1/8(1045)	NA	NA	41 1/8 (1045)
	Distance between front legs and splashguard	8 (203)	8 (203)	8 (203)	8(203)
Elect	rical Service (Field Electrical Wiring Connection)				
(D)	RH End of case to center of Field Electrical Wiring Connection (bottom of case)	30 ³ / ₈ (772)	54 ³ / ₈ (1381)	78 1/2 (1994)	126 5/8 (3216)
	Back of case to center of Field Electrical Wiring Connection	25 1/2 (648)	25 ¹ /2(648)	25 ¹ /2(648)	25 ¹ /2(648)
	Length of electrical wireway	32 1/2 (826)	22 ¹ /2(572)	32 ¹ /2(826)	32 1/2 (826)
(E)	RH end of case to LH end of electrical wireway (bottom of case)	44 1/8 (1121)	68 ¹ /4(1734)	92 1/4 (2343)	140 ¹ /2(3569)
Wast	e Outlets				
(F)	RH End of case to the center of waste outlet	24 1/8 (613)	24 1/8 (613)	24 1/8 (613)	72 1/4 (1835)
	Back O/S of case to center of waste outlet(s)	33 ¹ /2(851)	33 ¹ /2(851)	33 ¹ /2(851)	33 ¹ / ₂ (851)
	Schedule 40 PVC drip pipe	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)
Refri	geration Outlet				
(G)	Back of case to center of refrigeration outlet	29(737)	29(737)	29(737)	29(737)
	End of case to center of refrigeration outlet	8 ¹ /2(216)	8 ¹ /2(216)	8 ¹ /2(216)	8 ¹ /2(216)

Electrical Data

Number	of Fans		4 ft	6 ft	8 ft	12 ft				
7.0-in.			1	2	2	3				
				Amp	oeres			Wa	itts	
Evapora	tor Fan		4 ft	6 ft	8 ft	12 ft	4 ft	6 ft	8 ft	12 ft
120V	60Hz	Energy Efficient	0.14	0.27	0.27	0.41	9	18	18	27
230V	50/60Hz	Energy Efficient	0.07	0.14	0.14	0.21	9	18	18	27
Minimun	n Circuit A	Ampacity								
120V	60Hz	Energy Efficient	0.34	0.47	0.47	0.61				
230V	50/60Hz	Energy Efficient	0.27	0.34	0.34	0.41				
Maximu	m Over Cı	Irrent Protection								
120V			20	20	20	20				
230V			15	15	15	15				

Lighting

ONLY LIGHTING CONFIGURATIONS THAT ARE COMPLIANT WITH THE U.S. DEPT. OF ENERGY (DOE) 2017 REGULATION ARE AVAILABLE FOR SALE FOR USE IN THE U.S.A.

	Amperes			Watts				
	4 ft	6 ft	8 ft	12 ft	4 ft	6 ft	8 ft	12 ft
STANDARD LIGHTING EcoShine II Canopy								
1 Row EcoShine II	0.16	0.26	0.32	0.48	19.3	31.6	38.6	58.0
	0.10	0.20	0.02	0.40	10.0	01.0	00.0	00.0
OPTIONAL LIGHTING								
EcoShine II Canopy								
1 Row EcoShine II HO	0.22	0.33	0.44	0.66	26.5	39.5	53.0	79.4
EcoShine II Shelf								
1 Row of Shelves	0.08	0.12	0.16	0.25	9.9	14.1	19.8	29.7
2 Rows of Shelves	0.16	0.23	0.33	0.49	19.8	28.2	39.5	59.3
EcoShine II Rail Light								
1 Row	0.08	0.12	0.16	0.25	9.9	14.1	19.8	29.7

120V Lighting Circuit Total = Standard Lighting + Total Optional Lighting + Optional Shelf Lighting 230V Lighting Circuit Total = Multiply 120V Lighting Circuit Total by 0.52

ENDS Each standard end adds 1 ½ in. (38 mr view end with end b	PHYSIC/ Merchandiser Drip F Schedule 4 Merchandiser Liquid Merchandiser Suctio	0 PVC d Line (in.)	1 ¹ /4 ³ /8 ⁵ /8				
ESTIMATED SHIPPING WEIGHT †							
Case					Solid End	t k	
	4 ft	6 ft	8 ft	12 ft	(each)		
lb (kg)	600 (272)	800 (363)	1000 (454)	1200 (544)	75 (34)		
† Actual weights will vary according to optional kits included.							

Shelf Options

Approved shelf sizes for standard (horizontal, 2-3 position brackets) displays:

12-inch 14-inch 16-inch 18-inch 20-inch

Contact engineering for non-standard (4 position brackets or other) display recommendations.

Minimum number of Shelves: 1

Optimal number of Shelves: 2

Maximum number of Shelves: 2

Maximum number of Lighted Shelves: 2

Standard shelf complement for test purposes: (2) rows of shelves (12 in., 18 in.) evenly distributed vertically.

Replacement Parts List


Part #	Description	Part #	Description			
FAN ASSEMBLIES		Coils				
Standard HE Far	n Assembly	0534323	4 ft, 8 ft, 12 ft			
4 Ft, 6 Ft, 8 Ft &	12 Ft	0534222	6 ft only			
0535562	7.0-in. Fan Assembly					
0534013	Fan Speed Controller (6 ft only)	Нолеусомв - Юніт	E			
		0538222	4 ft, 8 ft, 12 ft			
FAN SPEED KEY		0538221	6 ft only			
0534365	1700 RPM					
		THERMO-EXPANSION	VALVE			
THERMOSTATS		Pre-set Adjustable				
OPTIONAL		Varies with	Refrigerant and Size			
LED FIXTURES AND	POWER SUPPLY					
0501213	Power Supply					
	LED Canopy Fixture					
	Replace with like fixtures.					
	LED Shelf Fixture					
	Replace with like fixtures.					

NOTE: For LED lighting parts contact your Hussmann service representative at 1-800-922-1919. Please have your model and serial number available. Descriptions including size and color are at http://www.hussmann.com/ EN/PRODUCTS/LED-LIGHTING/PAGES/DEFAULT.ASPX.

LED Rail Fixture

Replace with like fixtures.

For additional parts information, visit http://www.hussmann.com/en/Pages/Aftermarket-Parts.aspx



WARNING

All components must have mechanical ground, and the merchandiser must be grounded.


 R = Red
 Y = Yellow
 G = Green
 BL = Blue
 BK = Black
 W = White

 = 120V Power
 O = 120V Neutral
 $\frac{1}{2}$ = FIELD GROUND
 mm = Case GROUND

8 of 10

Optional LED Shelf Lighting

Optional Shelf Harness and LED Light Circuits for 2 Rows of Lighted Shelves



WARNING

All components must have mechanical ground, and the merchandiser must be grounded.

R = Red	Y = Yellov	/ G = Green	BL = Blue	BK = B	lack	W = White
• = 120V Pov	VER O =	120V Neutral	± = Field G	ROUND	mm =	CASE GROUND

Estimating Refrigeration and Electrical Load (for comparison purposes only)

Case Btu

To determine Btu for a case, refer to the performance data chart on page 2. Select lit or unlit shelves, then select the type of remote refrigeration system (parallel or conventional), which will give Btu/hr/ft. Multiply this number by the length of the case to determine Btu per hour.

Case Electrical

Refer to store legend to determine number of circuits. Lighting should be specified in store legend.

Fan electrical load for a case is computed by selecting the case length and fan voltage on page 6. For example, a 12 ft case uses 3 fans. The store legend specifies fans on a 230V circuit. In this instance, fans use 0.21 Amps and the MCA is 0.41. When applied, ambient fans, anti-sweat heaters, controllers, etc. must be included in the MCA. Include lights in the MCA if lights are on same circuit.

Lights may be on a separate circuit. To estimate lighting load: select case length (12 ft), canopy lighting [standard or optional] (here 0.70 for standard), and shelf or rail lighting [maximum for which case is wired] (0.49 for two shelves); then add together [0.48 + 0.49 = 0.97 amps for 120V] (for 230V, multiply 0.97 * 0.52 = 0.51).

Line Sizing — Refer to store legend.

Hussmann Line Sizing Charts are engineered for use with Hussmann refrigeration equipment.



Scan QR code to access product information on your mobile device.

Revision History

Revision A: May 2014: Original Issue

Revision B: May 2015: Fixed incorrect part number on the cover.

Revision C: July 2015: Fixed incorrect part number.

Revision D: December 2015: Updated cross section and plan view.

Revision E: April 2016: Updated cover image, updated application data, added Gross Refrigerated Volume and updated plan view.

Revision F: August 2016: Updated cross section and plan view.

Revision G: January 2017: Added rail light updates.

Revision H: April 2017. Updated LED energy values.

Revision J: April 2017. Updated LED energy values.

Revision K: September 2017. Updated notes page.

Revision L: February 2018. Updated cross section and plan view.