

NSF Certification

This merchandiser model is manufactured to meet NSF/ANSI (National Sanitation Foundation) Standard #7 requirements for construction, materials and cleanability.

Performance Data Product Data (AHRI Statistics)	Page 2 Page 2	Estimated Shipping Weights Shelf Options	Page 7 Page 7
Cross Section	Page 4	Wiring Diagrams	Page 8
Plan View	Page 5	Computing Refrigeration and Electrical Load	Page 11
Electrical Loads	Page 6	QR Code for Parts and Product Information Revision History	Page 11 Page 11

Data sheet-Insight IDF5NM

We reserve the right to change or revise specifications and product design in connection with any feature of our products. Such changes do not entitle the buyer to corresponding changes, improvements, additions or replacements for equipment previously sold or shipped.

	IDF5NM		Energy Comparison			
	Application	Dairy/Deli/ Beverage/ Produce	Convertible/ Meat	NSF Type ² Ambient ³	Pegs⁴	AHRI 1200 Rating Point⁵
	Discharge Air °F (°C)	33 (0.55)	31 (-0.55)	30 (-1.11)	32 (0)	34 (1.11)
Unlit Shelves	Average Evaporator °F (°C) ²	28 (-2.22)	27 (-2.77)	26 (-3.33)	26 (-3.33)	30 (-1.11)
	Parallel Btu/hr/ft (Watts/m) ⁸	1055 (1015)	1110 (1068)	1320 (1269)	1375 (1323)	1020 (981)
	Conventional Btu/hr/ft (Watts/m) ⁸	1150 (1106)	1210 (1164)	1440 (1385)	1500 (1443)	1110 (1068)
	Discharge Air °F (°C)	31 (-0.55)	30 (-1.11)	29 (-1.66)	N/A	33 (0.55)
Lit	Average Evaporator °F (°C) ²	27 (-2.77)	26 (-3.33)	25 (-3.88)	N/A	29 (-1.66)
Shelves	Parallel Btu/hr/ft (Watts/m) 6,8	1070 (1029)	1130 (1087)	1345 (1293)	N/A	1030 (991)
	Conventional Btu/hr/ft (Watts/m) 6,8	1165 (1121)	1230 (1183)	1465 (1409)	N/A	1125 (1082)
Fan Snood ⁷	IDF5NM6 (8.25")	1400	1600	1600	1400	1400
Fan Speed ⁷	IDF5NM4, 8, 12 (8.25")	1400 ⁷	1600 ⁷	1600 ⁷	1400 ⁷	1400 ⁷

Notes:

1. All data based on store temperature and humidity that does not exceed NSF Type 1 ambient conditions of 75°F and 55% relative humidity except where noted.

2. Average evaporator temperature shown. Use dew point for high glide refrigerants for unit sizing. Care should be taken to use the dew point in PT tables for measuring and adjusting superheat. Adjust evaporator pressure as needed to maintain discharge air temperature shown.

3. Data for operation in NSF Type 2 ambient of 80°F and 55% relative humidity.

4. Hussmann Peg Shelves for Dairy/Deli applications only.

5. AHRI 1200 Rating Point for energy consumption comparison only.

6. Add 10 Btu/hr/ft (9.6 Watts/m) per shelf row for LED shelf light fixtures.

7. Some lengths and/or applications require optional fan speed control kits applied by the Hussmann Product Configurator.

8. Subtract 60 BTU/hr/ft (57.7 watts/m) for front glass (on applicable models).

Defrost Data Conventional Controls Frequency (hours between defrost) 4 Low Pressure Backup Control CI/CO¹⁰ Defrost Water 9 8.2 lb/ft/day 20°F /10°F (12.2 kg/m) -6.7°C/-12.2°C Indoor Unit Only, ⁹ (± 15% based on case configuration and product loading). Pressure Defrost Termination ¹⁰ OFFTIME 48°F (8.9°C) Time (minutes) 20 ¹⁰ Use a Temperature Pressure Chart to determine PSIG conversions. Not Available ELECTRIC OR GAS

Product Data

Gross Refrigerated Volume ¹¹ (Cu Ft/Ft) AHRI Total Display Area ¹² (Sq Ft/Ft) Shelf Area ¹³ (Sq Ft/Ft)

9.6 ft³/ft (0.89 m³/m) 4.27 ft²/ft (1.30 m²/m) 8.11 ft²/ft (2.47 m²/m)

¹¹ AHRI Gross Refrigerated Volume: Refrigerated Volume/Unit of Length, ft³/ft [m³/m]

¹² Computed using AHRI 1200 standard methodology: Total Display Area, ft² [m²]/Unit of Length, ft [m]

¹³ Shelf surface area is composed of bottom deck plus standard shelf complement for this model: (4) rows of 18-in. shelves

Refrigeration Data Continued

Total Working Refrigerant Charge ¹⁴

Air-Cooled

With Recommended Condensing Unit Installed

4 ft	5 lb, 6 oz	/	2.45 kg
6 ft	7 lb	/	3.18 kg
8 ft	7 lb, 6 oz	/	3.36 kg
12 ft	8 lb, 13 oz	/	4.00 kg

Water-Cooled

With Recommended HMDSLMT Condensing Unit Installed

4 ft	3 lb, 10 oz	/	1.63 kg
6 ft	3 lb, 13 oz	/	1.73 kg
8 ft	4 lb	/	1.82 kg
12 ft	5 lb, 2 oz	1	2.32 kg

¹⁴ The Total Refrigerant Charge includes the case and condensing unit. Both ship pre-charged with a portion of the total refrigerant.

Insight **IDF5NM** Dairy / Delicatessen / Meat

Insight Multideck Merchandiser, 5 Display Levels, Narrow Bottom, Medium Height Front

DOE 2017 Energy Efficiency Compliant Hussmann refrigerated merchandisers configured for sale for use in the United States meet or surpass the requirements of the DOE 2017 energy efficiency standards.

Shelf complement shown as tested:

Four rows of 18-in. shelves spaced equally between bottom display pan and interior top panel.


Other optional kits (top piping and vent fans) add to the overall case height.

A minimum 1 ¹/₂-in. clearance required to remove raceway cover, 6 ¹/₂-in. for full access. See the Installation manual for instructions.

3-in. between back to back cases.


Shown with Flat Front Fascia Option and Bumper.

OPTIONAL RAIL LIGHT




Rail light cannot be used with glass front option.

OPTIONAL GLASS FRONT



Glass front cannot be used with rail light option.




NSF Certification

This merchandiser model is manufactured to meet NSF/ANSI (National Sanitation Foundation) Standard #7 requirements for construction, materials and cleanability.

Engineering Plan View

Insight IDF5NM Dairy / Delicatessen / Meat

Dimensions shown as in. and (mm).



FRONT

(12 Foot Model shown above)

		4 ft	6 ft	8 ft	12 ft
Gene	ral				
(A)	Case Length (without ends or partitions) (Each end and insulated partition adds $1^{1/2}$ in. (38 mm) to case line up.)	48 1/8 (1222)	72 1/4 (1835)	96 1/4 (2445)	144 3/8 (3668)
	Maximum O/S dimension of case back to front (includes bumper)	38 5/8 (981)	38 5/8 (981)	38 5/8 (981)	38 5/8 (981)
	Back of case to front of splashguard	30 5/8 (778)	30 5/8 (778)	30 5/8 (778)	30 5/8 (778)
(B)	Distance between edges of external legs and center legs	NA	29 (737)	41 (1041)	41 (1041)
(C)	Distance between edges of center legs	41 1/8 (1045)	NA	NA	41 1/8 (1045)
	Distance between front legs and splashguard	3 1/4 (83)	3 1/4 (83)	3 1/4 (83)	3 1/4 (83)
Elect	rical Service (Field Electrical Wiring Connection)				
(D)	RH End of case to center of Field Electrical Wiring Connection (top of case)	39 5/8 (1006)	63 5/8 (1616)	87 7/8 (2232)	135 3/8 (3451)
	Back of case to center of Field Electrical Wiring Connection	15 ³ /8 (391)	15 ³ /8 (391)	15 3/8 (391)	15 3/8 (391)
	Length of electrical wireway	44 5/8 (1133)	33 ¹ / ₂ (851)	45 ⁷ /8 (1165)	45 7/8 (1165)
(E)	RH end of case to LH end of electrical wireway (top of case)	46 1/2 (1181)	70 1/2 (1791)	94 ¹ / ₂ (2400)	142 5/8 (3630)
Wast	e Outlets				
(F)	RH End of case to the center of waste outlet	24 1/8 (613)	24 1/8 (613)	24 1/8 (613)	72 1/4 (1835)
	Back O/S of case to center of waste outlet(s)	28 5/8 (727)	28 5/8 (727)	28 5/8 (727)	28 5/8 (727)
	Schedule 40 PVC drip pipe	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)	1 1/4 (32)
Refri	geration Shroud				
(G)	Back of case to center of refrigeration shroud	22 7/8 (581)	21 1/8 (537)*	22 7/8 (581)	22 7/8 (581)
	End of case to center of refrigeration shroud *6 ft case at a 42° angle parallel to the plenum	9 ¹ / ₂ (241)	7 5/8 (194)*	9 ¹ / ₂ (241)	9 ¹ / ₂ (241)

Insight IDF5NM Dairy / Delicatessen/ Meat

Electrical Data

Number of Fans 8.25 in.		4 ft 1	6 ft 2	8 ft 2	12 ft 3			
		Amp	eres			Wa	tts	
Evaporator Fan	4 ft	6 ft	8 ft	12 ft	4 ft	6 ft	8 ft	12 ft
120V 60Hz Energy Efficient	0.25	0.50	0.50	0.75	16	32	32	48
230V 50/60Hz Energy Efficient	0.13	0.26	0.26	0.39	16	32	32	48
Condensate Pump								
120V 60Hz	1.9	1.9	1.9	1.9				
230V 60Hz	1.0	1.0	1.0	1.0				
Minimum Circuit Ampacity								
120V 60Hz Energy Efficient	2.83	2.96	3.08	3.33				
230V 50/60Hz Energy Efficient	1.58	1.65	1.71	1.84				
Maximum Over Current Protection								
120V	20	20	20	20				
230V	15	15	15	15				

Lighting

ONLY LIGHTING CONFIGURATIONS THAT ARE COMPLIANT WITH THE U.S. DEPT. OF ENERGY (DOE) 2017 REGULATION ARE AVAILABLE FOR SALE FOR USE IN THE U.S.A.

	Amperes			Watts				
	4 ft	6 ft	8 ft	12 ft	4 ft	6 ft	8 ft	12 ft
STANDARD LIGHTING								
LED Canopy								
1 Row	0.16	0.26	0.32	0.48	19.3	31.6	38.6	58.0
OPTIONAL LIGHTING								
LED Canopy			~			00 F		70.4
1 Row HO	0.22	0.33	0.44	0.66	26.5	39.5	53.0	79.4
LED Shelf								
1 Row of Shelves	0.08	0.12	0.16	0.25	9.9	14.1	19.8	29.7
2 Rows of Shelves	0.00	0.12	0.10	0.23	9.9 19.8	28.2	39.5	29.7 59.3
						-		
3 Rows of Shelves	0.25	0.35	0.49	0.74	29.7	42.3	59.3	89.0
4 Rows of Shelves	0.33	0.47	0.66	0.99	39.5	56.4	79.1	118.6
5 Rows of Shelves	0.41	0.59	0.82	1.24	49.4	70.5	98.9	148.3
6 Rows of Shelves	0.49	0.70	0.99	1.48	59.3	84.5	118.6	178.0
LED Rail Light								
1 Row	0.08	0.12	0.16	0.25	9.9	14.1	19.8	29.7
-			•					

120V Lighting Circuit Total = Standard Lighting + Total Optional Lighting + Optional Shelf Lighting 230V Lighting Circuit Total = Multiply 120V Lighting Circuit Total by 0.5

Each standard end adds 1 ½ in. (38 m	S or PARTITIONS I and each insulated p Im) to case line up. Op bumper adds 3 ³ /4 in. (otional		PHYSIC Merchandiser Drip Schedule 4 Merchandiser Liqui Merchandiser Sucti	l0 PVC d Line (in.)	1 ¹ /4 ³ /8 ⁵ /8			
	ESTIMATED SHIPPING WEIGHT †								
Case					Solid End	ł			
	4 ft	6 ft	8 ft	12 ft	(each)				
lb (kg)	870 (395)	1080 (490)	1280 (581)	1490 (676)	100 (45))			
+ Actual weights will	vary according to optional	kits included.							

Shelf Options

Approved shelf sizes for standard (horizontal, 2-3 position brackets) displays:

14-inch 16-inch 18-inch

Contact engineering for non-standard (4 position brackets or other) display recommendations.


Minimum number of Shelves: 3

Optimal number of Shelves: 4

Maximum number of Shelves: 8


Maximum number of Lighted Shelves: 6

Standard shelf complement for test purposes: (4) rows of 18-in. shelves evenly distributed vertically.



Optional Shelf Lighting—LED Fixtures

Optional Shelf Harness and LED Light Circuits for 2 or 3 Rows of Shelves




WARNING

All components must have mechanical ground, and the merchandiser must be grounded.

R = RedY = YellowG = GreenBL = BlueBK = BlackW = White• = 120V Power• = 120V Neutral \downarrow = Field Groundmm = Case Ground

Optional Shelf Lighting—LED Fixtures

Optional Shelf Harness and LED Light Circuits for 6 or 7 Rows of Shelves



WARNING

All components must have mechanical ground, and the merchandiser must be grounded.

R = RedY = YellowG = GreenBL = BlueBK = BlackW = White● = 120VPower○ = 120VNeutral↓ = FieldGroundmm = CaseGround

Estimating Refrigeration and Electrical Load (for comparison purposes only)

Case Btu

To determine Btu for a case, refer to the performance data chart on page 2. Select lit or unlit shelves, then select the type of remote refrigeration system (parallel or conventional), which will give Btu/hr/ft. Multiply this number by the length of the case to determine Btu per hour.

Case Electrical

Refer to store legend to determine number of circuits. Lighting should be specified in store legend.

Fan electrical load for a case is computed by selecting the case length and fan voltage on page 6. For example, a 12 ft case uses 3 fans. The store legend specifies fans on a 230V circuit. In this instance, fans use 0.39 Amps and the SSMCA is 1.84. When applied, ambient fans, anti-sweat heaters, controllers, etc. must be included in the MCA. Include lights in the MCA if lights are on same circuit.

Lights may be on a separate circuit. To estimate lighting load: select case length (12 ft), canopy lighting [standard or optional] (here 0.70 for standard), and shelf or rail lighting [maximum for which case is wired] (1.48 for six shelves); then add together [0.48 + 1.48 = 1.96 amps for 120V] (for 230V, multiply 1.96 * 0.52 = 1.02).

Line Sizing — Refer to store legend.

Hussmann Line Sizing Charts are engineered for use with Hussmann refrigeration equipment.



Scan the QR code with your mobile device to access additional product information or order parts.

Parts may also be ordered at: parts.hussmann.com Call toll free: 1.855.487.7778

Revision History

Revision A: May 2016: Original Issue

Revision B: August 2016: Updated cross section and plan view.

Revision C: January 2017: Added rail light updates.

Revision D: April 2017. Updated LED energy values.

Revision E: April 2017. Updated LED energy values.

Revision F: September 2017. Updated notes page.

Revision G: October 2018. Updated refrigerant charges.

Revision H: August 2020. Updated refrigeration and electrical data; updated wiring diagrams.